



WESTLOCK
CONTROLS CORPORATION

BEACON™ MONITOR INSTALLATION AND OPERATIONS MANUAL

IOM: Tech-205		Revision: B	
Prepared By: C. Spence	Date: 11/19/10	Drafting Work Order: 19007	ECN: 11650
Reviewed By: J. Kilian	Date: 11/30/10	Approved By: Rhonda Frey	Date: 11/30/10
This IOM contains confidential information and is issued in confidence on the condition that it be returned on demand and not be copied, reproduced, disclosed to others or used in manufacture of the subject matter thereof without the written consent of Westlock Controls			

WESTLOCK CONTROLS CORPORATION
280 MIDLAND AVENUE, SADDLE BROOK, NJ 07663 TEL: 201-794-7650 FAX: 201-794-0913

www.westlockcontrols.com

Revision History

Revision

- Rev. A. 8/20/05 • Rev. B. 11/19/10

Initial release

Westlock Controls Offices

USA

Westlock Controls Corp.

280 North Midland Ave. Saddle Brook, NJ 07663

Phone: (201) 794-7650 • Fax: (201) 794-0913

Email: westlockinfo@westlockcontrols.com

Internet: <http://www.westlockcontrols.com>

Westlock Service Center

6735 Exchequer Dr.

Suite 100

Baton Rouge, LA 70809

Phone: (225) 296-8118 • Fax: (225) 296-5188

Email: stevesmith@westlockcontrols.com

Europe

Westlock Controls UK

Chapman Way, Tunbridge Wells

Kent, England TN23EF

Phone: 011-44-189-251-9046 • Fax: 011-441-892-516279

Email: sales@westlockuk.com

Internet: <http://www.westlockuk.com>

South America

Westlock Equipamentos De Controles Ltda.

Rua, Sao Paulo 291

Alphaville, Barueri

Sao Paulo, CEP 06465-130

Phone: 011-55-11-7291-0930 • Fax: 011-55-11-7291-0931

Email: comercial@westlock.com.br

Internet: <http://www.westlock.com.br/>

WESTLOCK CONTROLS CORPORATION

280 MIDLAND AVENUE, SADDLE BROOK, NJ 07663 TEL: 201-794-7650 FAX: 201-794-0913

www.westlockcontrols.com

TABLE OF CONTENTS

1.	<i>Introduction.....</i>	4
1.1.	<i>Product Certification.....</i>	4
1.2.	<i>Warnings.....</i>	4
1.3.	<i>Description.....</i>	4
1.4.	<i>Principles of Operation.....</i>	4
1.5.	<i>Special Features.....</i>	4
2.	<i>Order Guide.....</i>	5
3.	<i>Definitions.....</i>	5
4.	<i>Installation.....</i>	6
5.	<i>Field Wiring.....</i>	10
6.	<i>Maintenance and Repair.....</i>	10
7.	<i>Appendix.....</i>	10

WESTLOCK CONTROLS CORPORATION

280 MIDLAND AVENUE, SADDLE BROOK, NJ 07663 TEL: 201-794-7650 FAX: 201-794-0913

www.westlockcontrols.com

1. Introduction

1.1. Product Certification

There are no applicable agency approvals, product markings, operating pressure specifications or electrical ratings for this product group. The operating temperature range for all Beacon products is -40C to +85C but range may be restricted when used on other products with agency approval due to agency testing requirements.

1.2. Warnings

Consult official Westlock Controls catalogue literature page WESMC-0577 for list of known chemical exposures that can be tolerated by the Beacon product. Consult factory before exposing the product to any chemicals or environments not listed therein to prevent risk of product degradation. There are no applicable electrical hazards or pinch hazards on this product when installed per factory specifications. Adhere to installation torque specifications for mounting screws to avoid damaged to the product that may permit ingress of contaminants into the sealed Beacon assembly.

1.3. Description

The Westlock Beacon provides visual, mechanically linked valve position monitoring that can be seen from up to 150 feet away in any direction.

1.4. Principles of Operation

The Westlock Beacon contains an inner cylinder, concentric outer cylinder, seal and, when required, a coupler. The inner cylinder mechanically couples to the shaft of the rotary Westlock control unit directly or to a rotary actuator, with the use of a coupler or beacon shaft. The inner cylinder rotates with the shaft of the actuator or control/monitoring unit and is labeled with the possible flow paths or positions. The outer cylinder of the Beacon has alternating clear windows and shrouded areas which reveal the appropriate valve status or flow path markings for the current valve position, while shrouding other markings. Mounting hardware fixes the outer cylinder to the Westlock control unit housing or actuator mounting bracket. The seal prevents ingress of substances between inner and outer cylinder that could impede the function of the beacon or cloud the viewing windows.

1.5. Special Features

There are no special features applicable to the Beacon product.

WESTLOCK CONTROLS CORPORATION

280 MIDLAND AVENUE, SADDLE BROOK, NJ 07663 TEL: 201-794-7650 FAX: 201-794-0913

www.westlockcontrols.com

2. Order Guide

Standard Flowpaths

QUARTER TURN



STANDARD
(BLACK & YELLOW)




ANSI BLUE
(GAS-LOW HAZARD)



ANSI RED
(FIRE QUENCHING)

QUARTER TURN 3-WAY



180 DEGREE 3-WAY



Ordering Guide

Quarter Turn

BM2-Y (N/C)

Black Open/Yellow Closed*

BM2-B

ANSI Blue and White

BM2-RG (N/C)

Green Open/Red Closed*

BM2-R (N/C)

ANSI Red and White*

BM2-Y-FE (N/C)

Black Open/Yellow Closed, French and English Text*

Quarter Turn 3-Way

BM3-1 See Standard Flowpaths

BM3-3 See Standard Flowpaths

BM3-5 See Standard Flowpaths

180 Degree 3-Way

BM3-7 See Standard Flowpaths

BM3-9 See Standard Flowpaths

3. Definitions

Not applicable.

WESTLOCK CONTROLS CORPORATION

280 MIDLAND AVENUE, SADDLE BROOK, NJ 07663 TEL: 201-794-7650 FAX: 201-794-0913


www.westlockcontrols.com

4. Installation


2-Way, 90 degree BM2-Y(N/C) or BM2-RG(N/C) On Westlock Controls Unit

1. ASSEMBLE INNER BEACON TO OUTPUT SHAFT
2. PLACE THE O'RING IN THE STEPPED RECESS PROVIDED IN THE OUTER BEACON HOUSING BOTTOM SURFACE. HOLD THE O'RING IN POSITION AND PLACE THE OUTER BEACON HOUSING OVER INNER BEACON. ROTATE THE OUTER BEACON HOUSING TO OBTAIN GRAPHIC DISPLAY THAT MATCHES VALVE FLOW PATH AS ILLUSTRATED.

VALVE CLOSED = SINGLE COLOR OVERALL



VALVE OPEN = CHECKER BOARD PATTERN OVERALL




NOTE: FOR BEACON MONITORS WITH A BLACK OUTER BEACON HOUSING AND RED & GREEN INNER BEACON;

VALVE CLOSED = RED
VALVE OPEN = GREEN

3. SECURE THE OUTER BEACON HOUSING TO THE UNIT WITH (4) TRUSS HEAD SCREWS PROVIDED WITH ORIGINAL UNIT

IMPORTANT: DO NOT EXCEED 10 in-lb OF TORQUE FOR EACH SCREW TO SECURE OUTER BEACON.




WESTLOCK CONTROLS CORPORATION

280 MIDLAND AVENUE, SADDLE BROOK, NJ 07663 TEL: 201-794-7650 FAX: 201-794-0913


www.westlockcontrols.com

2-Way, 90 degree BM2-Y(N/C) or BM2-RG(N/C) On Actuator

1. ASSEMBLE "BAA" BRACKET KIT ONTO THE ACTUATOR, USING HARDWARE PROVIDED IN THE SAME KIT.
2. ASSEMBLE GROMMET INTO LARGE CENTER HOLE OF BRACKET.
3. ASSEMBLE BEACON SHAFT THROUGH GROMMET AND INTO ACTUATOR SHAFT SLOT OR INTO COUPLER FOR NON-NAMUR ACTUATORS.
4. ASSEMBLE INNER BEACON ONTO BEACON SHAFT.
5. PLACE THE O'RING IN THE STEPPED RECESS PROVIDED IN THE OUTER BEACON HOUSING BOTTOM SURFACE. HOLD THE O'RING IN POSITION AND PLACE THE OUTER BEACON HOUSING OVER INNER BEACON. ROTATE THE OUTER BEACON HOUSING TO OBTAIN GRAPHIC DISPLAY THAT MATCHES VALVE FLOW PATH AS ILLUSTRATED.



VALVE CLOSED = SINGLE COLOR OVERALL




VALVE OPEN = CHECKER PATTERN OVERALL

NOTE: FOR BEACON MONITORS WITH A BLACK OUTER BEACON HOUSING AND RED & GREEN INNER BEACON;

VALVE CLOSED = RED
VALVE OPEN = GREEN

6. SECURE THE OUTER BEACON HOUSING TO THE BRACKET WITH (4) HEX HEAD SCREWS, NUTS & WASHERS PROVIDED IN THE BEACON SHAFT/GROMMET KIT.

IMPORTANT: DO NOT EXCEED 10 in-lb OF TORQUE FOR EACH SCREW TO SECURE OUTER BEACON.



WESTLOCK CONTROLS CORPORATION


280 MIDLAND AVENUE, SADDLE BROOK, NJ 07663 TEL: 201-794-7650 FAX: 201-794-0913

www.westlockcontrols.com

All Other Beacons On Westlock Controls Units

1. ASSEMBLE COUPLER INTO INNER BEACON.
2. ASSEMBLE INNER BEACON WITH COUPLER TO OUTPUT SHAFT OF UNIT.
3. PLACE THE O'RING IN THE STEPPED RECESS PROVIDED IN THE OUTER BEACON HOUSING BOTTOM SURFACE. HOLD THE O'RING IN POSITION AND PLACE THE OUTER BEACON HOUSING OVER INNER BEACON. ROTATE THE OUTER BEACON HOUSING TO OBTAIN GRAPHIC DISPLAY THAT MATCHES VALVE FLOW PATH.
4. SECURE THE OUTER BEACON HOUSING TO THE UNIT WITH (4) TRUSS HEAD SCREWS PROVIDED WITH ORIGINAL UNIT.

IMPORTANT: DO NOT EXCEED 10 in-lb OF TORQUE FOR EACH SCREW TO SECURE OUTER BEACON.



WESTLOCK CONTROLS CORPORATION


280 MIDLAND AVENUE, SADDLE BROOK, NJ 07663 TEL: 201-794-7650 FAX: 201-794-0913

www.westlockcontrols.com

All Other Beacons On Actuator

1. ASSEMBLE "BAA" BRACKET KIT ONTO THE ACTUATOR, USING HARDWARE PROVIDED IN THE SAME KIT.
2. ASSEMBLE GROMMET INTO LARGE CENTER HOLE OF BRACKET.
3. ASSEMBLE BEACON SHAFT THROUGH GROMMET AND INTO ACTUATOR SHAFT SLOT OR INTO COUPLER FOR NON-NAMUR ACTUATORS.
4. ASSEMBLE COUPLER INTO INNER BEACON.
5. ASSEMBLE INNER BEACON WITH COUPLER ONTO BEACON SHAFT.
6. PLACE THE O'RING IN THE STEPPED RECESS PROVIDED IN THE OUTER BEACON HOUSING BOTTOM SURFACE. HOLD THE O'RING IN POSITION AND PLACE THE OUTER BEACON HOUSING OVER INNER BEACON. ROTATE THE OUTER BEACON HOUSING TO OBTAIN GRAPHIC DISPLAY THAT MATCHES VALVE FLOW PATH.
7. SECURE THE OUTER BEACON HOUSING TO THE BRACKET WITH (4) HEX HEAD SCREWS, NUTS & WASHERS PROVIDED IN THE BEACON SHAFT/GROMMET KIT.

IMPORTANT: DO NOT EXCEED 10 in-lb OF TORQUE FOR EACH SCREW TO SECURE OUTER BEACON.



WESTLOCK CONTROLS CORPORATION

280 MIDLAND AVENUE, SADDLE BROOK, NJ 07663 TEL: 201-794-7650 FAX: 201-794-0913

www.westlockcontrols.com

5. Field Wiring

Not applicable; the Westlock Beacon is not an electrical device.

6. Maintenance and Repair

None required.

7. Appendix

None

WESTLOCK CONTROLS CORPORATION

280 MIDLAND AVENUE, SADDLE BROOK, NJ 07663 TEL: 201-794-7650 FAX: 201-794-0913

www.westlockcontrols.com